

# TOF Hardware Status

---

## 1. Current Status

- Overview
- HV /LV
- FEM
- Cooling System / Temp. Monitor


## 2. Scheduled Items



**Tatsuya CHUJO**  
*Univ. of Tsukuba*

# Current Status - Overview -


- All LV Power supplies were installed in both North and South side (4/25 done)
- LV control and LV module's temperature readout at the counting house
- HV control by the serial connection (RS232C) and monitoring
- TOF temperature readout via ADAM system
- Cooling blowers for TOF
- ARCNET control (by Nevis Group)
- All 1920 channels readout using test pulse to FEM (timing and charge injection)
- Done all hardware installation in IR



**We are very close to say “TOF Operation Ready”!**

# High /Low Voltage Control


## High Voltage Control



Channel	HUmax	Umon	Imon	U0set	I0set	Pu	Status	Ch#
CHANNEL00	----	0001.20	----	1800.00	----	Off		0.00
CHANNEL01	----	0001.80	----	1800.00	----	Off		0.01
CHANNEL02	----	0000.80	----	1800.00	----	Off		0.02
CHANNEL03	----	0002.20	----	1800.00	----	Off		0.03
CHANNEL04	----	0001.00	----	1800.00	----	Off		0.04
CHANNEL05	----	0001.20	----	1800.00	----	Off		0.05
CHANNEL06	----	0001.00	----	1800.00	----	Off		0.06
CHANNEL07	----	0000.80	----	1800.00	----	Off		0.07
CHANNEL08	----	0000.60	----	1800.00	----	Off		0.08
CHANNEL09	----	0001.20	----	1800.00	----	Off		0.09
CHANNEL10	----	0001.20	----	1800.00	----	Off		0.10
CHANNEL11	----	0001.40	----	1800.00	----	Off		0.11
CHANNEL12	----	0001.20	----	1800.00	----	Off		0.12
CHANNEL13	----	0001.40	----	1800.00	----	Off		0.13
CHANNEL14	----	0001.20	----	1800.00	----	Off		0.14
CHANNEL15	----	0000.40	----	1800.00	----	Off		0.15

- We use well-established method for HV control and monitoring (serial connection) for Day-1, instead of EPIC control
- Set up dedicated PC for CAEN HV

## Low Voltage Control



- Controlled from PC for all 8 LV modules
- 6.8V output
- LV racks temperature monitoring
- Normal operation: LV ON (40~50 °C)

# FEM

- ☆ After LV crates installation, we have done
  - ARCNET control
  - Test pulse events data taking for all channels
  - Confirmed all FEM modules are working
  - FEM calibration parameters check for QVC, TVC (Yun-Ha) using test pulse events  
( $106 \text{ nsec}/64 = 1.7 \text{ nsec}$  time interval)



1920 signal cables are connected to FEM's

- ☆ Plan
  - Laser events data taking for all channels
    1. Check PMTs signals
    2. Timing adjustments, channel by channel
    3. Data taking with BBC
    4. Work with online monitoring

# Cooling System / TOF Temp. Monitor

- Cooling System (= Air blowers)  
Working well, but air ducts are vibrating during the blowers operation

## No mechanical damage for TOF itself


*How reduce/stop this vibration?*

- \* Solution 1 (Tom S.) Adjust fan speed and stop resonance in ducts?
- \* Solution 2 (Susumu S.) Put isolated plates both duct and fan and connect by flexible material?



*Will be fixed in May shutdown*

- TOF Temperature Monitor  
Working well, readout normal temperature (21~24 °C, turn off all HVs)



TOF Temperature monitor (ADAM system)

# Scheduled Items

---

- (0) TOF Operation Procedure for RUN2000, check and revise  
    ⇒ End of this week or early next week
- (1) Full operation chain test using laser input with BBC
- (2) Current sensors for blowers
- (3) Fix air ducts vibration in May shutdown
- (4) Online monitoring
- (5) Event display
- (6) DCM readout by TOF offline software, and reconstruct DST